



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180BO0350

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	SEAL FOR LIFE Industries BVBA Nijverheidsstraat 13, B-2260 Westerlo
Distributor <i>Vertreiber</i>	SEAL FOR LIFE Industries BVBA Nijverheidsstraat 13, B-2260 Westerlo
Product Category <i>Produktart</i>	greasing and sealing materials: Protection tape against corrosion (5180)
Product Description <i>Produktbezeichnung</i>	heat shrinkable wraparound sleeve, glass fibre reinforced
Model <i>Modell</i>	DIRAX
Test Reports <i>Prüfberichte</i>	laboratory control test: 18/016/5180/07 from 27.02.2018 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999) DIN 30672 (01.12.2000)

Date of Expiry / File No. 10.10.2023 / 18-0467-GNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

25.06.2018 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
DIRAX	stress-class: C HT 60 UV permanent operating temperature: ...+60 °C	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Application: with medium flame shrinking on wet epoxy primer

Designation according to standard: Coating EN 12068-C HT 60 UV and DIN 30672-C 60

DVGW